



STEAM TRAP INSTALATION
See ADPC.01.2167

DIMENSIONS (mm)	
A	_____
B	_____
C	_____
D	_____
E	_____
F	_____
G	_____
H	_____

* See IS catalogue

By pass should not be installed if there is the risk of damage due to over pressure.

8.1	01	ADCA MAN-100 Pressure gauge	DN_____	Range _____ - _____ bar
08	01	ADCA MAN-100 Pressure gauge	DN_____	Range _____ - _____ bar
07	02	ADCA GC-400 Gauge Cock	DN_____	---
06	02	ADCA GSC-40 Gauge siphon	DN_____	---
05	01	Safety valve	DN_____	Spring _____
4.2	01	ADCA VF 16 Globe valve	DN_____	---
4.1	01	ADCA VF 16 Globe valve	DN_____	---
04	01	ADCA VF 16 Globe valve	DN_____	---
03	01	ADCA IS16F Y Strainer	DN_____	---
02	01	ADCA S25S Humidify separator	DN_____	---
01	01	ADCA ADCA PRV47_____ Pressure reducing valve	DN_____	---

Ref.	Quant.	Deseqation / Designação	Size/Medidas	Material	Remarks / Observações
Data		Rubrica		Proc. 0.490	
Proj. 06/07/07		F.Soaeres		---	
Des. 06/07/07		Paulo S.		Des.N°: ADCR.02.2375	
Verif.				Rev: 01 Em: 08/09/19	
Escalas		Tolerancias / especificações / Dimensões / Desvios		Description / Descrição: PRESSURE REDUCING VALVE STATION CONJUNTO REDUTOR ARMADO PRV47S	